

ADDENDUM NO. 6

April 13, 2021

RE: **Renovations to Bailey APAC Middle School – South Wing**
 Jackson Public Schools
 Jackson, Mississippi
 A/E Project No. 18-032d

FROM: Eley Guild Hardy Architects
 329 Capitol Street
 Jackson, MS 39201
 (601) 354-2572

TO: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated February 24, 2021. Acknowledge receipt of this Addendum in the space provided on the Proposal Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of 1 page.

CLARIFICATIONS

1. Lead-Based Paint: Refer to the Asbestos and Lead-Based Paint Survey and Assessment report for where Lead-Based Paint occurs. Comply with all aspects of disturbance and disposal of Lead-Based Paints per the report.

CHANGES TO PROJECT MANUAL

1. Section 01 21 00 – Allowances: Under ‘1.2 Allowances’, Paragraph ‘B. Contingency (Latent Conditions) Allowance’, Paragraph ‘1.a’ revised text reading “Base Bid: Thirty-Five Thousand Dollars (\$35,000)” to read “Base Bid: Forty Thousand Dollars (\$40,000)”.

CHANGES TO DRAWINGS

1. Sheet S101 – Structural General Notes: Under ‘Epoxy Injection Notes’ add the following note: “5. For Base Bid the contractor shall provide **1,000 linear feet** of epoxy injection in locations as noted and indicated on the construction documents. Contractor shall document and track (*and submit to Architect/Engineer*) the linear footage of **all** epoxy injections for the project by marking on the associated plans/elevations/photos the location and photographing the linear footage with a tape measure in place. Epoxy Injection locations not shown on construction documents and/or locations that exceed the stated overall base bid linear footage shall be submitted with the required documentation to Architect/Engineer for review and approval before proceeding with the epoxy injections at these locations.”

END OF ADDENDUM 6