

ADDENDUM #2 – DELAWARE PLAZA RENOVATIONS

The following changes and/or clarifications are hereby made to the above captioned Contract Documents as originally dated April, 2022. Wherever the original Contract Documents are inconsistent herewith, the provisions of the Addendum shall govern.

Item #1 – Roof / Floor Framing: Roof and floor framing for the façade structure shall be No. 2 SYP **2x10** Framing at 16” on center. Provide blocking or ‘x’ bracing at mid-span.

Item #2 – Exterior Finish and Soffit: Exterior finish and soffit are to be stucco systems as specified in Division 7. Disregard notations on the drawings that are contrary to this.

End of Addendum #2