

**ADDENDUM**

**Number:** Four (4)

**Date:** May 3, 2022

**Project:** GS# 101-320 Campus ADA Improvements  
(Package A – Elevator)  
Alcorn State University  
Lorman, MS  
RFx #3160004909

**CCD Project No.** Project No. 20005

**Copies To:** All bid document holders of record

---

The following changes, additions, deletions, and/or clarifications to the Project Manual (including the Specifications) and Drawings dated October 6, 2021, Addenda Number One (1) dated March 31, 2022; Addenda Number Two (2) dated April 5, 2022; Addenda Number Three (3) dated April 20, 2022, are hereby made part of the Contract Documents. Receipt of this addendum shall be acknowledged by inserting its number and date in the Bid Proposal Form where indicated. Failure to acknowledge this Addendum will result in rejection of your bid proposal.

**REFER TO THE SPECIFICATIONS**

- 1.1 Section 009000 Addenda. This Addendum shall be added to Section 009000 Addenda and become a part of the Standard Form of Agreement Between the Owner and Contractor.
- 1.2 Section 055223 Architectural Glass Railing System. Refer to article 2.3 paragraph E:
  - a. Subparagraph 1. Change tempered glass to laminated glass.
  - b. Subparagraph 2. Change thickness to ¾ inch.

**REFER TO THE DRAWINGS**

- 1.3 Drawing number Z03-3.5 Finish Schedule, remove Z03-24 Women (Toilet) this room is not in this scope of work.
- 1.4 Drawing number 1 Campus Student Union – Enlarged Plan – First Floor on Z03-3.5: Add room number Z03-13.6 in the area located North of East Lobby Z03-11 and located between the stairs and toilets.

**END OF ADDENDUM NUMBER FOUR (4)**

**CANIZARO CAWTHON DAVIS**

Submitted by:



Jared Pierce, AIA  
Principal